

memo

DATE: April 18, 2023
TO: Motley
FROM: Steve Robertson
Supervisor, Source Water Protection Unit
SUBJECT: Statewide Perfluoroalkyl Substances (PFAS) Monitoring Project

Below please find your system's sampling results for the Statewide PFAS Monitoring Project. Sampling was conducted on 9/23/22.

Sampling results

PFAS contaminant detected	Maximum concentration (µg/L) ¹	MDH health value (µg/L)
PFBA	0.0019	7

All sampling results were below the available health-based guidance values for PFAS. A person drinking water at or below the guidance value would have little or no risk for health effects.

Next Steps

Since PFAS sampling is not required by the EPA, you are not required to include these results in your consumer confidence report (CCR). However, MDH recommends that you include them in your next CCR and can provide resources to help you give context about what these results mean.

About the project

Minnesota Department of Health (MDH) has been studying the potential health impacts of PFAS in groundwater in Minnesota since 2002. This project is part of a larger effort at MDH to sample all community water systems (CWSs) for PFAS. MDH aims to cover 90% of CWS customers under its PFAS monitoring program by 2025. The project has been made possible through funding from the Clean Water Fund and U.S. Environmental Protection Agency. Sampling results from all systems that participated in the study will be included in an interactive mapping application on the MDH website. MDH will also be providing these results to the Minnesota Pollution Control Agency to make them aware of the contamination.

¹ One microgram per liter is the same as one part per billion (ppb).

PFAS RESULTS MEMO

- For more information about the PFAS monitoring in Minnesota, please visit [PFAS Testing of Public Water Systems](https://www.health.state.mn.us/communities/environment/water/pfas.html) (<https://www.health.state.mn.us/communities/environment/water/pfas.html>).
- For more information about Phase I of this project, see the infosheet [Statewide PFAS Monitoring Project \(PDF\)](https://www.health.state.mn.us/communities/environment/water/docs/statewidepfas.pdf) (<https://www.health.state.mn.us/communities/environment/water/docs/statewidepfas.pdf>).

If you have any questions about the results, please contact Jane de Lambert, the Project Manager, at (651)201-4692.

cc: Jenny Soltys, MDH District Engineer
Attachment

Minnesota Department of Health
PO Box 64975
St. Paul, MN 55164-0975
651-201-4700
health.drinkingwater@state.mn.us
www.health.state.mn.us

4/18/2023

To obtain this information in a different format, call: 651-201-4700.